



2019 WATER QUALITY REPORT



Battisti Water System

Public Water Supply ID# NY4100061

January 1 to December 31, 2019

This report complies with Part 5-1.72, New York State Sanitary Code (10 NYCRR) and federal Consumer Confidence Report regulations (40 CFR Part 141, Subpart O).

Introduction:

New York American Water (NYAW) is issuing this report describing the quality of drinking water supplied to customers of the Battisti Water District. NYAW has been selected to be the contracted operator of the Battisti water system as per administrative order by the New York State Public Service Commission.

A Message from the New York American Water President



To Our Valued Customer:

Thank you for the opportunity to serve you. Our team at New York American Water takes our job of serving you safe, clean drinking water every day very seriously and we are proud to be your local water service provider.

I am pleased to share our **Annual Water Quality Report** with you – this is our report card on the quality of the drinking water delivered to our customers. The report shows that we continue to supply you with water that meets or surpasses all county, state and federal water quality standards. New York American Water invests in our infrastructure to ensure the delivery of quality drinking water. This includes the facilities and technology needed to draw water from the source and treat it, along with miles and miles of pipeline hidden below the ground to bring water to your tap. In addition, our plant operators, water quality experts, engineers and maintenance crews work around the clock to make sure that quality water is always there when you need it.

Delivering safe, reliable water service requires significant investment to maintain and upgrade aging facilities. **In 2019, we invested approximately \$55.5 million in system improvements across the state.** New York American Water is also acting proactively to prepare for proposed regulation of emerging compounds, such as 1,4-Dioxane and PFOA/PFOS, by the New York State Department of Health.

Water is essential for public health, fire protection, economic development and overall quality of life. New York American Water's employees are committed to ensuring that quality water keeps flowing not only today, but well into the future.

We encourage our customers to review this report as it provides important details about the source and quality of your drinking water between January and December 2019.

Thank you for allowing us to serve you. **WE KEEP LIFE FLOWING.**

Sincerely,

Lynda DiMenna
President, New York American Water



About New York American Water

New York American Water, a subsidiary of American Water (NYSE: AWK), is the largest investor-owned water company in New York, providing high-quality and reliable water and/or wastewater services to approximately 350,000 people.

About American Water

With a history dating back to 1886, American Water is the largest and most geographically diverse U.S. publicly traded water and wastewater utility company. The company employs more than 6,800 dedicated professionals who provide regulated and market-based drinking water, wastewater and other related services to more than 15 million people in 46 states. American Water provides safe, clean, affordable and reliable water services to our customers to make sure we keep their lives flowing. For more information, visit amwater.com and follow American Water on [Twitter](#), [Facebook](#) and [LinkedIn](#).

Where does our water come from?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the number of certain contaminants in water provided by public water systems. The State Health Departments and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves a population of approximately 160 people through 53 service connections. Our water source is two groundwater wells located north of the intersection of Northern Blvd and Orchard Rd. Each well is approximately 40 feet in depth into the Schodack Aquifer. The water is chlorinated at the source prior to entry to the distribution system.

The New York State Department of Health has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state's source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. While nitrates (and other inorganic contaminants) were detected in our water, it should be noted that all drinking water, including bottled water, may be reasonably expected to contain at least small amounts of some contaminants from natural sources. The presence

of contaminants does not necessarily indicate that the water poses a health risk. See the section, "Are there contaminants in our drinking water?" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

The county and state health departments will use this information to direct future source water protection activities. These may include water quality monitoring, resource management, planning and education programs. A copy of the assessment, including a map of the assessment area, can be obtained by contacting us at the telephone number provided in this report.

Are there contaminants in our drinking water?

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at 800-426-4791, or the Rensselaer County Department of Health at 518-270-2632

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include total coliform, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, and synthetic organic compounds. The tables presented on the next page depict which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

Definitions:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).



QUALITY. ONE MORE WAY WE KEEP LIFE FLOWING.

Micrograms per liter (µg/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

N/A: Not applicable.

Nanograms per liter (ng/l): Corresponds to one part of liquid to one trillion parts of liquid (parts per trillion - ppt)

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Picocuries per liter (pCi/L): A measure of the radioactivity in water

Water Quality Results

Table of Detected Contaminants

Contaminant and Unit of Measurement	Dates of Sampling (mo/yr)	MCL Violation Y/N	Level Detected	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants (at Point-of-Entry location)						
Nitrate, mg/l	07/2019	N	1.6	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

¹ Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Disinfectant/ Disinfection Byproduct (D/DBP) Parameters (taken in the Distribution System)							
Contaminant and Unit of Measurement	Date of Sample (mo/yr)	Violation Y/N	Level Detected	Range	MCLG	MCL	Likely Source of Contamination
TTHM [Total Trihalomethanes], µg/L	10/2019	N	ND	N/A	N/A	80	By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter.
HAA [Haloacetic Acids], µg/L	10/2019	N	ND	N/A	N/A	60	By-product of drinking water chlorination needed to kill harmful organisms. HAA's are formed when source water contains large amounts of organic matter.
Disinfectants (Test results from the Entry Point to the distribution system location)							
Chlorine, mg/l	2019	N	1.2 (average)	0.2 - 2.2	NA	MRDL = 4	Water additive used to control microbes.

Lead and Copper Rule (Tap water samples were collected from 10 customer homes in the service area)

Contaminant (units)	Date Sampled	Action Level	MCLG	Amount Detected (90th %tile)	Range: Low-High	Homes Above Action Level	Violation	Typical Source
Copper(ppm) ²	07/2019 10/2019	1.3	1.3	0.03 0.08	0.01 - 0.03 0.04-0.09	0	NO	Corrosion of household plumbing systems.
Lead, (ppb) ²	07/2019 10/2019	15	0	ND 1.22	ND - ND ND - 1.23	0	NO	Corrosion of household plumbing systems.

² The level presented represents the 90th percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead and copper values detected at your water system. In this case, 10 samples were collected at your water system and the 90th percentile value was the second highest value. The action level for lead was exceeded at one of the sites tested. The action level for copper was not exceeded at any of the sites tested.

**If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. NYAW is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

What does this information mean?

Our system had one violation in 2019. We failed to collect six lead and copper samples in the first half of the year, prior to New York American Water operating this system. Please see note 2 above explaining the potential health effects and precautions. We will be collecting 10 samples the first half of the year in 2020, followed by another 10 samples in the second half of the year to assure compliance.

Is our water system meeting other rules that govern operations?

During 2019, our system was not in compliance with all applicable New York State drinking water operating, monitoring, and reporting requirements.



QUALITY. ONE MORE WAY WE KEEP LIFE FLOWING.

Do I Need to Take Special Precautions?

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium*, *Giardia* and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

Why Save Water and How to Avoid Wasting It?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- Saving water saves energy and some of the costs associated with both of these necessities of life;
- Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire-fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. Get a run for your money and load it to capacity.
- Turn off the tap when brushing your teeth.
- Check every faucet in your home for leaks. A slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you can save more than 30,000 gallons a year.

New York American Water is offering a free 'leak detection kit' for home use. If desired, please call our 24-hour customer call center at 877-426-6999 and request one.

Thank you for allowing us to continue to provide your family with quality drinking water this year. We ask that all our customers help us protect our water sources. For questions concerning this report or your water quality, please contact Michael Nofi, Water Quality Manager, at 1-516-632-2215; Environmental Consultants at 1-845-486-1030 at or New York American Water's customer call center at 1-877-426-6999; or on the web at newyorkamwater.com.



QUALITY. ONE MORE WAY WE KEEP LIFE FLOWING.