

Annual Drinking Water Quality Report for 2019
Painted Apron Water System
Port Jervis, NY, 12771
Public Water Supply ID # NY3503621

INTRODUCTION

To comply with State and Federal regulations, the Painted Apron Water System will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact JCO, Inc, at 845-888-5755. We want you to be informed about your drinking water. If you want to learn more, please contact the system owner to discuss drinking water issues in person.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include microbial contaminants, inorganic contaminants, pesticides and herbicides, organic chemical contaminants, and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations, which limit the number of certain contaminants in water provided by public water systems. The State Health Departments and the FDA's regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system serves 32 homes. These homes are located in the City of Port Jervis, Orange County. Our water source is groundwater drawn from one drilled well. The well is drilled in gravel aquifers. The well that is used produces 10 gallons per minute (gpm). The well supplies water to the distribution system composed of 6-inch and 8-inch diameter water mains. After proceeding through the chlorinator, the water is pumped to 10,000-gallon atmospheric storage tank, through one of the 6-inch diameter water mains. Two transfer pumps supply a 5000-gallon hydro-pneumatic pressure tank from the 10,000-gallon atmospheric tanks. The 5000-gallon pressure tank supplies water to a 6-inch water main serving the entirety of the system. The well house is located on Painted Apron Terrace where all the wells are located as well.

The NYSDOH has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See "Table of Detected Contaminants" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

As mentioned before, our water is derived from one drilled well. The source water assessment has rated these wells as having a medium-high susceptibility to microbials. This rating is due primarily to the close proximity of the low-level residential activity and the septic system that are located in the assessment area. In addition, the wells draw from fractured bedrock and an unconfined aquifer of unknown hydraulic conductivity and the overlying soils are not known to provide adequate protection from potential contamination. While the source water assessment rates our well as being susceptible to microbials, please note that our water is disinfected to ensure that the finished water delivered into your home meets New York State's drinking water standards for microbial contamination.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include total coliform, inorganic compounds, nitrate, lead and copper, volatile organic compounds, disinfection byproducts, radiologicals, and synthetic organic compounds. The attached table depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Orange County Health Department at 845- 291-2331.

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, MRDL or AL)	Likely Source of Contamination
Barium	No	03/12/18	0.043	mg/l	2	MCL = 2	Erosion of natural deposits.
Trihalomethanes (TTHMs)	No	08/2017	22.0	ug/l	N/A	MCL = 80	Byproduct of drinking water disinfection needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter.
Haloacetic Acids (HAA5)	No	08/2017	8.40	ug/l	N/A	MCL = 60	
Sodium	No	04/24/19	58.9	mg/l	N/A	See Note 1	Road salt
Total Coliform Bacteria (See note 2)	No	July 2019	1 Positive Sample	N/A	0	TT= 2 or more positive samples/month	Naturally present in the environment.
Copper (See note 3)	No	Sept 2019	90 th = 1.18 Range= (0.06- 1.54)	mg/l	1.3	AL= 1.3	Corrosion of household plumbing systems
Lead (See note 4)	No	Sept 2019	90 th = ND Range= (ND - 1.11)	ug/l	0	AL= 15	Corrosion of household plumbing systems.

Notes:

- 1-- Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.
- 2- All required repeat samples did not confirm the presence of coliform bacteria.
- 3- The level presented represents the 90th percentile of the 5 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, 5 samples were collected at your water system and the 90th percentile value was the average of the two highest values. The action level for copper was exceeded at one of the sites tested.
- 4- The level presented represents the 90th percentile of the 5 samples collected. The action level for lead was not exceeded at any of the sites tested.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

Millirems per year (mrem/yr): A measure of radiation absorbed by the body.

Treatment Techniques (TT): A required process intended to reduce the level of a contaminant in drinking water.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations, but we have learned through our testing that some contaminants have been detected; however, these contaminants were detected below New York State requirements.

We are required to present the following information on lead in drinking water:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. It is possible that lead levels in your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. NYAW is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1.800.426.4791) or at <http://www.epa.gov/safewater/lead>.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2019, our system was in compliance with State drinking water operating, and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium*, *Giardia* and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

Special Message about proposed Regulation of Emerging Contaminants by New York State Dept of Health:

What are Emerging Compounds?

1,4-Dioxane is a synthetic industrial chemical that is present in many goods, including paint strippers, dyes, greases, antifreeze and aircraft deicing fluids, and in some consumer products such as deodorants, shampoos and cosmetics.

PFOA/PFOS are Per- and polyfluoroalkyl substances (PFAS) which are a group of man-made chemicals. PFAS have been manufactured and used in a variety of industries around the globe, including in the United States since the 1940s. PFAS can be found in:

- Food packaged in PFAS-containing materials, processed with equipment that used PFAS, or grown in PFAS-contaminated soil or water.
- Commercial household products, including stain- and water-repellent fabrics, nonstick products (e.g., Teflon), polishes, waxes, paints, cleaning products and fire-fighting foams (a major source of groundwater contamination at airports and military bases where firefighting training occurs).

- Workplace, including production facilities or industries (e.g., chrome plating, electronics manufacturing or oil recovery) that use PFAS.

Today's Drinking Water Standards for Emerging Compounds

Currently, the U.S. Environmental Protection Agency (EPA) has established guidance for the presence of PFOA/PFOS in drinking water. The EPA has established a non-enforceable health advisory level of 70 parts per trillion (ppt) for the sum of PFOA and PFOS. No federal maximum contaminant level (MCL) for 1,4-Dioxane in drinking water has been established.

New York American Water meets all current federal, state and local drinking water standards.

New York State Department of Health's (NYSDOH) Proposed Regulation of Emerging Compounds

The New York State Department of Health has indicated that they are looking to establish regulations for PFOA/PFOS and regulations for 1,4-Dioxane sometime in 2020. In anticipation of these regulations, New York American Water is acting proactively to identify the presence of these emerging compounds in our water supply well sources and design, permit, and construct the appropriate treatment where needed.

NYSDOH Proposed Maximum Contaminant Levels (MCL's):

- 1,4-Dioxane = 1.0 parts per Billion (NYAW-Painted Apron PWS has no wells above the 1.0 ppb proposed MCL)
- PFOA/PFOS = 10.0 parts per Trillion for each parameter (NYAW- Painted Apron PWS has no detections of these contaminants)

New York American Water's Action Plan

New York American Water is acting proactively to ensure we are prepared for New York State's proposed regulations of PFOA/PFOS and 1,4-Dioxane when they are finalized. Additional information will be provided to customers as the New York State Department of Health provides guidance on their proposed regulation of these emerging compounds.

For more information, visit www.nyamwater.com/water-quality/water-safety

Click here for announcements from the NYS Governor on regulation of emerging compounds in drinking water and consumer products.

<https://www.governor.ny.gov/news/governor-cuomo-announces-availability-350-million-water-system-upgrades-statewide-and-directs>

<https://www.governor.ny.gov/news/governor-cuomo-signs-legislation-help-prevent-water-contamination-14-dioxane>

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.

- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children’s future. Please call our office if you have questions.

<p>Spanish Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.</p>	<p>French Ce rapport contient des informations importantes sur votre eau potable. Traduisez-le ou parlez en avec quelqu'un qui le comprend bien.</p>
<p>Korean 아래의 보고는 귀라에서 드시는 식수에 대한 중요한 정보가 포함되어 있습니다. 번역은 필요하지 않다면 이 보고를 읽은 이래라시는 분나 말씀하시기를 바랍니다.</p>	<p>Chinese 這份報告含有非常重要有關您喝的水的資料 請找懂得這份報告的人翻譯或解釋給您聽</p>